

FORM - A

(Form of application under sub-section (1) sub-section (2) of section 4 of the Madras Public Buildings (Licensing) Act, 1965, (Madras Act 13 of 1965) referred to in rule 3 of the Madras Public Buildings (Licensing Rules 1966).

From :

**M/s.Vijay Vikas International School,
Organised & Run by Lakshmi Balaji Educational and Charitable Trust,
Vijayamangalam.**

To : The Tahsildar,

**Perundurai Taluk Office,
Perundurai Taluk, Erode District.**

Sir,

I intend/to use the buildings/to continue to use the existing public building/to use the existing building not at present used as a public building/which is situated in the site or plot of land.
Town or Revenue : R.S.F.No : 121/2-Part, Kambiliyampatti Village & Panchayat, Near
Vijayamangalam Toll, Kambiliyampatti, Perundurai Taluk, Erode District and specified in the statement enclosed, is a public building for the period of
3 Years effect from 01/04/2025 to 31/03/2028

2. The years of construction and the present approximate cost of construction and the purpose for which it is to be used or being used as public building are also furnished in the statement accompanying this application.

3. I enclosed a challan for Rs.

4. I also enclose a certificate of structural soundness in the prescribed form furnished by the Engineer. **Er.K.KUMARAGURUPARAN, B.E., M.I.E., F.I.V., M.I.C.A., P.G.Dip(VAL),**

Date : 20/03/2025


MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056

Signature of Owner/Occupier of the Building


M. FRANCIS, M.A., B.Ed., M.Phil.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638056.



Ref.No : KKG/KPM/PBSC/008

Date : 20/03/2025

STATEMENT ACCOMPANYING FORM - A


1. Name " M/s.Vijay Vikas International School"
Vijayamangalam
Door Number of the Building --
2. Location (Street Number, ward Number, Name of Place, I.e., Corporation/Municipality/Township/ R.S.F.No : 121/2 - Pt, Kambiliyampatti Village & Panchayat, Near Vijayamangalam Toll, Kambiliyampatti, Perundurai Taluk, Erode District.
3. Year of Construction 2014 (11 Years)
4. Approximate cost of construction as per current Rs.5,00,00,000.00
(Rupees Five Crore Only)
5. Purpose for which the building is being used or Proposed to be used RCC Class Rooms, Library, Toilet, Lab, Staff Room, Principal Room & Computer Lab
6. Purpose for which the building has either to been used RCC Class Rooms, Library, Toilet, Lab, Staff Room, Principal Room & Computer Lab
7. Details for construction of the building
(Particulars of the foundation soil. Specification of the various parts under
i) Foundation : RCC Column Footing & R.R Masonry in CM
ii) Basement : RCC Plinth Beam with Brick Work in CM
iii) Superstructure : RCC Column with Brick Work in Cement Mortar
iv) Floor and Roof : RCC Flat Roof with Vitrified Tiles
8. Period for which license is required : effect from 01/04/2025 to 31/03/2028
9. Carpet Area of the building
(Carpet Area of the RCC Class Rooms & Staff Room) : 13728.00 Sft
- 10.No. of persons to be accomodated (including all) : 1372 Nos


Date: 20/03/2025

Signature of the Engineer

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or it portion of the building originally is changed or altered sub-sequently.

Date : 20/03/2025


MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) 638 056


Signature of the Owner of the building
M.FRANCIS, M.A., B.Ed., M.Phil.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638056.

FORM - B

(Form of certificate of Structural Soundness Under-section (4) of section 4 of the Madras Public Buildings (Licensing) Act, 1985 (Madras Act 13 of 1985), referred to in rule 4 of the Madras Public Buildings (Licensing) Rules, 1980)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features :-

(1) Foundation :

- | | | |
|---|---|-------------|
| i. Depth below ground level | : | 2.44 M |
| ii. Nature of soil met with at foundation | : | Hard Moorum |
| iii. Pressure at foundation | : | 35 T/Sqm |
| iv. Probable safe bearing capacity of the strata met with at foundation | : | 45 T/Sqm |

(2) Superstructure :

- | | | | | |
|--|---|---------------------|---|-----------------------|
| i. Maximum stress in the most critical section of masonry and concrete | : | Concrete : 45 T/Sqm | : | Masonry : 400 kgs/sqm |
| ii. Nature of masonry and concrete and safe premissible stress | : | Concrete : 60 T/Sqm | : | Masonry : 450 kgs/sqm |


The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (Latest version) and other relevant indian standards code of Practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A licence may granted for the period of 3 Years effect from 01/04/2025 to 31/03/2028

Date : 20/03/2025

Signature of the Engineer
District Panel Engineer Class - 1A




MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056


M. FRANCIS, M.A., B.Ed., M.Phil.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638056.

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS**


Location of the Building	R.S.F.No : 121/2-Part, Kambillyampatti Village & Panchayat, Near
D.No. St., and build.of the place	Vijayamangalam Toll, Kambillyampatti, Perundurai Taluk, Erode District
Age of the building	11 Years (2014)
Number of Storeys	Upto First Floor
Short description of structure-steel R.C.C. Framed of load bearing Masonry	RCC Framed Structure
Purpose for which the building is Certified for use sound	RCC Class Rooms, Library, Toilet, Lab, Staff Room, Principal Room & Computer Lab
The period for which the building will be structurally	effect from <u>01/04/2025</u> to <u>31/03/2028</u>
No. of persons to be accomadated(including all)	1372 Nos


**THIS CERTIFICATE WILL NOT HOLD GOOD IN TIMES OF NATURAL CALAMITIES
LIKE FIRE, FLOOD AND EARTH QUAKE ETC.**

- Note 1) This stability certificate contains 10 pages including Erode District class 1A Panel Engineer certificate copy and Namakkal District Class – I Panel Engineer Certificate Copy and 03 Nos of Blue Prints which is prepared by me, with Ref.No: KKG / KPM / STA – PLAN /007, Dated : 20 / 03 / 2025
- 2) Any Construction and alteration activities should not be carried out on working Hours & days.
- 3) Periodical Maintenance Should be Carried Out Regularly..
- 4) Permanent structures (having roof) are only covered in this stability certificate.
- 5) Grouting Should be done in G.F & F.F Toilet walls, to arrest the masonry & R.C.C Beam Joints.
- 6) Weathering Coarse on the Second Floor (Everywhere Water Stagnation are found, that water seeping in RCC Roof) that has to be rectified.
- 7) Expansion joint on both side are to be well treated (Maintained) without water seepage. First Floor Latrines tiles joint and wash basin, bottom are to be sealed with water proof materials, because of that Ground floor RCC roof and beam at Staircase are getting damaged.
- 8) The above 3 Points (5, 6, 7) all to be carried out with in 3 month time are otherwise this Certificate will not hold good.

Date : 20/03/2025


MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056


Er. KKUMARAGURUPARAN
M. Sc., M. Ed., M. Phil.,
Principal Panel Engineer Class - 1A
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056



FORM - D

(Form of certificate of Structural Soundness Under section (4) of section 4 of the Madras Public Buildings (Licensing) Act, 1955 (Madras Act 13 of 1955), referred to in rule 4 of the Madras Public Buildings (Licensing) Rules, 1955)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features :

(1) Foundation :

- i. Depth below ground level : 2.44 M
- ii. Nature of soil met with at foundation : Hard Moorum
- iii. Pressure at foundation : 35 T/Sqm
- iv. Probable safe bearing capacity of the strata met with at foundation : 45 T/Sqm

(2) Superstructure :


- i. Maximum stress in the most critical section of masonry and concrete : Concrete : 45 T/Sqm
Masonry : 400 kgs/sqm
- ii. Nature of masonry and concrete and safe permissible stress : Concrete : 60 T/Sqm
Masonry : 450 kgs/sqm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (Latest version) and other relevant Indian standards code of Practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A licence may granted for the period of 3 Years effect from 01/04/2026 to 31/03/2028

Date: 20/03/2026

Signature of the Engineer
District Panel Engineer Class - 1A




MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056


M. FRANCIS, M.A., B.Ed., M.Phil.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638056.

DECLARATION

I, K.KUMARAGURUPARAN, son of Sri.K.K.A.Kandasamy, 32, Sivagnanam Street, Opp. to Kamatchi Kalyana Mandapam, Bhavani - 638 301, do hereby declare that I possess the qualification experience specified in the fable to rule II of the Madras public buildings (Licensing) Rules, 1966 for issuing the certificate of structural soundness of the building covered by the certificate. Also under the G.O. MS No. 97 Municipal Administration and Water Supply (M.A.4) Department Dated 16.07.2001

- 1) This Report does not include any eventualities caused due to natural calamities
- 2) we hereby advice that periodical repairs and renovations shall be carried out to the entire building blocks regularly by every year and intimating me through writing
- 3) Further necessary fire fighting equipments should be kept in the premises and should be trained for for operation. If any fire accident/mishap occurs we are not held responsible.
- 4) Emergency exit to be provided as per norms
- 5) All electrical points, wiring/Gadgets has to checked properly and to be maintained periodically. For this, competent engineer is not held responsible for electrical defaults.
- 6) If any violation is found at a later stage after issue of this report, we are not held responsible and this report gets cancelled.
- 7) Further, this report covers the certification for the particular blocks, Floors only mentioned in the Plan - Legal aspects are not considered.

DISTRICT PANEL ENGINEER FOR :


Erode District Panel Engineer Class I-A
(R.Dis.No: 22659/2007 C2)

Namakkal District Panel Engineer Class I
(R.Dis.No: 6073/99)


Station : KOMARAPALAYAM

Date : 20/03/2025

SIGNATURE OF THE CERTIFYING ENGINEER




MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056


M. FRANCIS, M.A., B.Ed., M.Phil.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampullyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638056,

PROCEEDINGS OF THE DISTRICT COLLECTOR, ERODE
PRESENT: THIRU T.UDHAYACHANDRAN, I.A.S.,

23/6/07

R.Dis. No. 25659/2007 C2

Dated: 21.6.2007

Sub: Tamil Nadu Public Buildings Licensing Act 1966 -
Panel of Private Practicing Engineers - Inclusion of the
name of Thiru K.Kumaraguruparan - In the Panel of
Private Practicing Engineer under Class I-A (One-A) -
Category in Erode District - Orders issued.

- Ref: 1. Engineer-In-Chief, WRO & Chief Engineer
(General) P.W.D. Chennai Letter No
AEE/T1/JE/38051/06 dated: 31.5.2007.
2. Board of Engineers Proceedings No. BOE-18
Dated 30.5.2007.

ORDER:

Under the provisions of Rule 11 of the Tamil Nadu Public Buildings
Licensing Rules 1966, the name of Thiru K.Kumaraguruparan, residing at
'K.K.A.K.Illam', 32 Sivagnanam Street, Opp. To Kamatchi Amman Kalyana
Mandapam, Bhavani 638 301, Erode District is hereby included in the Panel of
Registered Engineers under Class I-A (One-A) Category in Erode District for the
purpose of issuing Structural Soundness Certificate of Public Buildings (Buildings
cost which exceeds Rs.30 Lakhs (Rupees Thirty Lakhs and above) with
reference to the Tamil Nadu Public Building Licensing Act 1965 and the Rules
covered there under.

(Sd.)T.Udhayachandran.
District Collector,
Erode

/True Copy/By Order/

For Collector

To

Er. K.Kumaraguruparan,
K.K.A.K.Illam,
32 Sivagnanam Street,
Bhavani 638 301.

Copy to: Superintending Engineer (PWD) Building Division, Erode.

Copy to: Engineer-In-Chief WRO and Chief Engineer (General) PWD,
Chepauk, Chennai 600 005.

Copy to: The Sub Collector, Gobichettipalayam

Copy to: Tahsildar, Bhavani.

Copy to: Stock File of C2/L5



[Signature]

MANAGER
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056

[Signature]

M. FRANCIS, M.A., B.Ed., M.Phil.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638056.

PROCEEDINGS OF THE DISTRICT COLLECTOR, NAMAKKAL,

PRESENT: THIRU. DAYANAND KATARIA, I.A.S.,

R.Dis.6073/99 (C3)

Dated: 11.11.99.

Sub: Tamil Nadu Public Buildings (Licensing) Act, 1965 -
Namakkal District - Drawing of Panel of
Registered Engineers under rule - Inclusion of
the name of Thiru K. Kumarakurubaran in the Panel
of Private Practising Engineers under Class I
Category in Namakkal District.

- Ref: 1. Application of Thiru K. Kumarakurubaran,
dated 5.2.99.
2. Chief Superintending Engineer (PWD) Buildings
(C&M) Salem, letter No. 554 M/F73/99 VA 6,
dated 21.7.99.
3. Engineer in Chief W.R.O. & Chief Engineer (General)
P.W.D. letter No. ABE/T1/JE/36464/97, dt. 30.8.99.
4. Board of Engineer's proceedings 371/18-98,
dated 24.2.98.

In accordance with the instructions of the Engineer in
Chief, W.R.O & Chief Engineer (General), Public Works Department,
Chennai in the reference 3rd and 4th cited, the name of
Thiru K. Kumarakurubaran, B.E., M.I.E., F.I.V., M.I.C.A.,
F.I.C.I., 10, J.K.K. Road, Near Head Post Office, B. Kumara-
palayam, Tiruchengode Taluk, Namakkal District is included
in the panel of Private Practising Engineers under the
Category of Class-I in Namakkal District for the purpose of
issuing structural soundness certificate for Public Buildings
in Namakkal District under the purview of the Tamil Nadu Public
Buildings Licencing Act, 1965.


District Collector,
Namakkal.

To

Thiru K. Kumarakurubaran, B.E.,
10, J.K.K. Road,
Near Head Post Office,
B. Komarapalayam -638 183,
Tiruchengode Taluk.

MANAGER

VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate
Perundurai, Erode (Dt) - 638 056



M. FRANCIS, M.A., B.Ed., M.Phil.,
PRINCIPAL
VIJAY VIKAS INTERNATIONAL SCHOOL
Kampuliyampatty,
Near Vijayamangalam Toll Gate,
Perundurai, Erode (Dt) - 638056.